Received on
24/08/26
from Principal

Shanker Laboratories

F-277, Flatted Factory Complex, Captain Gaur Marg,
(Near Okhla NSIC Metro Station), Okhla, New Delhi - 110020

Known for Excellency in Testing

TEST REPORT

Dated: 21 August 2026
Report No: 33934

Name & contact of Customer: M/s. Notre dame School Kair VPO- Najafgarh New Delhi-110043
Dt. of Receipt: 18.08.2026
Nature of Sample: Water
Sample ID: Drinking Water
Test period: 18 – 21 August 2026
Laboratory Mark: SL 33939-260817

S. No	Parameter	Unit	Results	Test Method	Acceptable Limits as per IS: 10500-2012	Conformity of sample Yes / No
1	Color Hz	Hz	1	IS 3025-Pt 4 2021	Not more than 5Hz	Yes
2	Sulphate SO_4	mg/L	32.00	IS 3025-Pt 24: Sec 1:2022	Not more than 200 mg/L	Yes
3	E Coli	Absent/Present	Absent	IS 1622: 1981	Absent	Yes
4	Total Coliform	Absent/Present	Absent	IS 1622: 1981	Absent	Yes

Conditions:
1. Results given above refer only to the sample supplied.
2. The report is being issued on the specific understanding that Shanker Laboratories will not in any way be Involved in any action following the interpretation of the above results.
3. This report shall not be reproduced, except in full, without the written permission of CEO, Shanker Laboratories, New Delhi..
4. Retention period of sample is 30 days as per ensuring the report.

Pooja Kumari
Reviewed by

Mr. Neeraj Katyal
Authorized Signatory

TC-15979

Shanker Laboratories

F-277, Flatted Factory Complex, Captain Gaur Marg,
(Near Okhla NSIC Metro Station), Okhla, New Delhi - 110020

Known for Excellency in Testing

TEST REPORT

Dated: 21 August 2026
Report No: 33934

Name & contact of Customer: M/s. Notre dame School Kair VPO- Najafgarh New Delhi-110043
Dt. of Receipt: 18.08.2026
Nature of Sample: Water
Sample ID: Drinking Water
Test period: 18 – 21 August 2026
Laboratory Mark: SL 33934-260818

S. No	Parameter	Unit	Results	Test Method	Acceptable Limits as per IS: 10500-2012	Conformity of sample Yes / No
1	pH@25^{0}c	--	7.50	IS 3025-Pt 11: 2022	6.5-8.5	Yes
2	Total Hardness as $CaCO_3$	mg/L	79.00	IS 3025-Pt 21: 2023	Not more than 200 mg/L	Yes
3	Calcium as Ca	mg/L	28.00	IS 3025-Pt 40: 2024	Not more than 75 mg/L	Yes
4	Magnesium as Mg	mg/L	5.80	IS 3025-Pt 46 : 2023	Not more than 30 mg/L	Yes
5	Total Alkalinity $CaCO_3$	mg/L	58.00	IS 3025-Pt 23 : 2023	Not more than 200 mg/L	Yes
6	Total Dissolved Salts TDS@ 180 ^{0}c	mg/L	103.0	IS 3025-Pt 16: 2023	Not more than 500 mg/L	Yes
7	Chloride Cl	mg/L	18.00	IS 3025-Pt 32: 2019	Not more than 250 mg/L	Yes
8	Turbidity	NTU	0.15	IS 3025-Pt 10:2023	Not more than 1	Yes
9	Odour	Agreeable/ Not Agreeable	Agreeable	IS 3025-Pt 5:2018	Agreeable	Yes
10	Iron Fe	mg/L	BDL (DL 0.01)	IS 3025-Pt 53: 2024	Not more than 0.3 mg/L	Yes
11	Specific Conductivity	µs/cm	190.0	IS 3025-Pt 14: 2023	-	-

Conditions:
1. Results given above refer only to the sample supplied,
2. The report is being issued on the specific understanding that Shanker Laboratories will not in any way be Involved in any action following the interpretation of the above results.
3. This report shall not be reproduced, except in full, without the written permission of CEO, Shanker Laboratories, New Delhi..
4. Retention period of sample is 30 days as per ensuring the report.

Mr. A.K Arora
Reviewed by

Mr. Neeraj Katyal
Authorized Signatory

MUNICIPAL CORPORATION OF DELHI
OFFICE OF DEPUTY HEALTH OFFICER
NAJAFGARH ZONE

मास्क का प्रयोग करें
दो गज़ की दूरी बनायें रखे
हाथ साबुन-पानी से अच्छे से धोयें

No: DHO/NGZ/MCD/2026/D- 119

Dated- 23/04/2026

SCHOOL HEALTH CERTIFICATE

1. Name of the School: - **NOTRE DAME SCHOOL**
2. SCHOOL ADDRESS:- **V.P.O.- KAIR,NAJAFGARH NEW DELHI-110043**
3. NO. OF SHIFT **ONE TIMING Morning. 08:00 AM TO 02:00 PM**
4. NO. OF STUDENTS: **BOYS- 619 GIRLS – 416 TOTAL = 1035**
5. NO. OF STAFFS: **MALE - 15 FEMALE – 40 TOTAL = 55**

Details of Accommodations present in School

1. Floor Space in the Classroom Sufficient/insufficient *SUFFICIENT*
2. The Classrooms are Well Lighted/ill lighted *WELL LIGHTED*
3. The Classrooms are Well Ventilated/ill ventilated *WELL VENTILATED*
4. The Classrooms are kept / Not kept Neat & Clean: *NEAT AND CLEAN*
5. The Building requires/does not required Whitewash etc. *NOT REQUIRED*
6. The Drinking Water is Wholesome/Not wholesome *WHOLESOME*
7. The Latrine arrangement is Sanitary/Insanitary *SANITARY FROM HEALTH POINT OF VIEW.*

No. of toilets seats for student

1. One latrine-cum-urinal is required for 25 female student, so total is *SUFFICIENT*
2. One latrine for 40 male student is required so total is *SUFFICIENT*
3. Separate Toilet arrangement for staff present: Yes/No *YES SEPARATE EXISTS FOR STAFF.*
4. The Overall facilities: Good/ Adequate/Inadequate *GOOD FROM HEALTH POINT OF VIEW.*

If building Department or any other govt. agency takes actions against u/a construction or any dispute, then the Health Certificate will be stand cancelled /revoked without any further intimation in this regard

Deputy Health Officer
Najafgarh Zone

Deputy Health Officer
Muncipal Corporation Of Delhi
Health Deptt., Najafgarh Zone

(Remarks: This Certificate is valid for one year from the date of issue and this has no bearing on any unauthorized construction)

Note: **- (This certificate Valid for School run in upper Ground + 3 upper floors only as per Fire NOC)**

Scanned with OKEN Scanner